

CA96

Date: October 7, 1997
 Ref: CA096-2
 Revision: 02
 Author: A.G.

Cable code	CA96
Description	UniOP PLC Port to Simatic S7-200
Type of Communication	RS-485
Panel Connector	D-sub type 15S
PLC Connector	D-sub type 9P
Notes	Can be used to connect old panel models type -0044 (TCA06 interface) to S7-300/400.

table 1. Cable description




figure 1. Cable diagram