

CA128

Date: February 13, 1997

Ref: Ca128-0

Revision: 00

Author:

Cable code	CA128
Description	UniOP AUX Port to MPI Port - RS-485
Type of Communication	RS-485
Panel Connector	D-sub type 9P
PLC Connector	D-sub type 9P
Notes	Compatible only with panels of type -0045 using TCM01 or TCM07. Use only for point-to-point connection in MPI systems. The Bus Connector 6ES7972-0BB20-0XA0 can be used for the PLC connector in order to provide the additional connection to the programming unit. The use of shielded connectors is recommended.

table 1. Cable description




figure 1. Cable diagram