

CA171

Date: May 24, 1999
 Ref: CA171-0.DOC
 Revision: 00

Cable code	CA171
Description	PLC Port to EV 2001 Terminal
Type of Communication	RS-485
Panel Connector	D-sub type 15S
PLC Connector	D-sub type 9P
Notes	This cable has been designed to connect to Cooperativa Bilanciai EV 2001 Weight Scale Terminal via its optional RS-485 interface. Proper grounding of all components in the systems is strongly recommended. Make sure UniOP is connected to Frame Ground shorting pin 2 and 3 of the power supply connector.

Table 1. Cable description




figure 1. Cable diagram