



## ■ XW2B-20J6-3B



This Servo Relay Unit connects to the following OMRON Programmable Controllers. Communications are not supported.


- CQM1-CPU43-V1
- CQM1H-PLB21 (Pulse I/O Board for CQM1H-CPU51/-CPU61)
- CS1W-HCP22

## ● External Dimensions



**Note** Terminal Block pitch: 7.62 mm

## ● Wiring



**Note 1.** If these signals are input, the CQM1 output pulse can be input into the High-speed Counter.

**Note 2.** Input this output signal to the CQM1 Input Unit.

**Note 3.** The XB contact is used to turn ON/OFF the electromagnetic brake.

**Note 4.** Phase Z is an open-collector output.

**Note 5.** Do not connect unused terminals.

**Note 6.** The 0-V terminal is internally connected to the common terminals.

**Note 7.** The following crimp terminal is applicable: R1.25-3 (round with open end).